


**Sedgwick County, Kansas – CDDO, Ark Valley Lodge
Americans with Disabilities Act Transition Plan
(615 N. Main)**

December 2006



Prepared by

**DMCG
Disability Management Consulting Group L.L.C.
(dba; ADA Accrediting and Consulting)
2801 Jonquil Place
Columbia, MO 65202**

In conjunction with

Sedgwick County and the Wichita/Sedgwick County Access Advisory Board

Sedgwick County – ADA/504 Transition Plan – CDDO, Ark Valley Lodge - December 2006 Legend: **Blue** font identifies hyperlinked documents – **Red** font indicates recommended changes to structures or policies

Locations		Structural Inconsistencies		Recommended Corrections/Modifications to Ensure Program Access			Criteria – L=low, M=medium, H=high			Supplemental Technical Information			Finalized Actions		
Location	Identified Issue	ADAAG Specifications	Recommended Correction	Priority (overall)	Public Access	Frequency - PWD	Photo #	Conceptual Costs	Support Information	Finalized Correction	Date to be Corrected	Date Completed (Include initial)			
1. Exterior – Pedestrian Path of Travel	A steep cross slope exists on the path of travel (sidewalk) from the County parking garage to the facility main public entrance.	4.3.7	According to ADAAG, nowhere shall the cross slope of an accessible route exceed 1:50. Modify the existing pedestrian path of travel or create accessible parking in front of the facility with an accessible path of travel.	L	L	L	1	\$10,000	See Building Block 5 – Curb Ramps for additional ADAAG specifications.						
2. Interior - General	Exit signs are not also provided in Braille.	4.1.3(16) 4.30.4	Signs that identify permanent rooms and spaces (exit signs, room numbers and restrooms) are required to be provided in Braille, mounted at 60-inches high measured to the center of the sign located at the latch side of the entrance door. In addition, the symbol of accessibility is required to exist at the entrance of accessible restrooms. Provide Braille signage where exit signs exist. Mount signage per the new ADAAG 703.4.	H	H	M	5	\$250	See Building Block 11 – Signage Specifications , for more information						
	All other aspects of this facility, interior and exterior, are fully accessible.														

Human Services, Ark Valley Lodge - Transition Plan - Conceptual Cost Projections

Total	\$10,250
Year One (Very High - VH)	\$0
Year Three (High - H)	\$250
Year Five (Medium - M)	\$10,000
Year Ten (Low - L)	\$0
Year Ten (Very Low - VL)	\$0