

RESOLUTION NO. 106-2015

Date Adopted: 05-20-2015

Date Published: 05-29-2015

Date Effective: 07-01-2015

A RESOLUTION ADOPTING THE INTERNATIONAL RESIDENTIAL CODE, PUBLISHED BY THE INTERNATIONAL CODE COUNCIL, INC., 2012 EDITION, AND AMENDING, ADDING, AND DELETING VARIOUS SECTIONS OF ARTICLE 2 OF THE WICHITA/SEDGWICK COUNTY UNIFIED BUILDING AND TRADE CODE.

WHEREAS, the Board of County Commissioners is authorized by K.S.A. 19-101 *et seq.* and 12-3303 *et seq.*, to officially adopt, incorporate, and promulgate by resolution codes, rules and regulations for air conditioning, refrigeration, warm air heating, and related trades within the confines of the unincorporated areas of Sedgwick County and those second- and third-class cities that have adopted those codes, rules, and regulations by action of their governing bodies and have entered into agreements with Sedgwick County related thereto; and

WHEREAS, effective January 1, 2013, Sedgwick County and the City of Wichita consolidated code enforcement from their respective jurisdictions within the Metropolitan Area Building and Construction Department ("MABCD") in Sedgwick County Resolution No. 135-2012 and City of Wichita Ordinance No. 49-333; and

WHEREAS, Sedgwick County, Kansas, and the City of Wichita, Kansas, have hereby adopted the Wichita-Sedgwick County Unified Building and Trade Code ("UBTC") within Resolution No. 175-2012 and Ordinance No. 49-412; and

WHEREAS, within the UBTC, Sedgwick County and the City of Wichita has previously adopted the International Residential Code, as published by the International Code Council, Inc., 2006 Edition, with additions, modifications, deletions, and omissions; and

WHEREAS, the MABCD Board of Code Standards and Appeals has reviewed and voted to approve all of the changes proposed in this Resolution; and

WHEREAS, the Board of County Commissioners of Sedgwick County, Kansas, finds that it has been advised by the Director of the MABCD, and therefore deems it necessary to amend the Article 2—Building Code portion of the UBTC by adopting the International Residential Code, published by the International Code Council, Inc., 2012 Edition, in place of the 2006 Edition of the same publication, with additions, modifications, deletions, and omissions as noted within this Resolution.

01-17
01-17
01-17

NOW, THEREFORE, BE IT RESOLVED THAT THE BOARD OF COUNTY COMMISSIONERS OF SEDGWICK COUNTY, KANSAS, AMENDS THE WICHITA-SEDGWICK COUNTY UNIFIED BUILDING AND TRADE CODE AS FOLLOWS:

SECTION 1.

SECTION 2.4.010. – Adoption of the International Residential Code *is amended to read as follows:*

The International Residential Code, as published by International Codes Council, Inc., 2012 Edition, is hereby adopted, subject to such amendments as set forth hereinafter.

SECTION 2.

SECTION 2.4.020 – Permit required *is amended to read as follows:*

R105.1 Required. Any owner or authorized agent who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, or to cause any such work to be done, shall first make application to the building official and obtain the required permit.

Wichita Jurisdiction Only

Whenever any work for which a permit is required by this Code has commenced without first obtaining said permit, a civil penalty fee up to the amount of the permit fee, as determined by the Code Official, shall be collected in addition to the permit fee.

SECTION 3.

SECTION 2.4.130. – Exterior Walls *is deleted.*

SECTION 4.

SECTION 2.4.135 – Three- and Four-family Dwellings *is added to read as follows:*

Sec. R302.3.2 of the International Residential Code is hereby added to read as follows:

Dwelling units in three- and four-family dwellings shall be separated from each other by a wall having not less than a two-hour fire-resistance rating. Fire-resistance-rated floor/ceiling and wall assemblies shall extend to and be tight against an exterior wall, and wall assemblies shall extend from the foundation to the underside of the roof sheathing.

The roof shall be a minimum of class C roof covering, and the roof decking or sheathing is of non-combustible materials or approved fire-retardant-treated wood for a minimum distance of two feet from the center of the wall. There shall be no penetrations through this area of the roof deck or sheathing.

Exception: Where buildings, or portions thereof, are arranged above or below adjacent units, an automatic sprinkler system shall be provided throughout all units.

SECTION 5.

SECTION 2.4.138 – Opening Protection *is added to read as follows:*

Section R302.5.1 of the International Residential Code is amended to read as follows:

R302.5.1 Opening protection. Openings from a private garage directly into a room used for sleeping purposes shall not be permitted. Other openings between the garage and residence shall be equipped with solid wood doors not less than 1 3/8 inches (35 mm) in thickness, solid or honeycomb-core steel doors not less than 1 3/8 inches (35 mm) thick, or 20-minute fire-rated doors.

SECTION 6.

SECTION 2.4.160 – Stairway illumination *is amended to read as follows:*

Section R303.7 of the International Residential Code is amended to read as follows:

R303.7 Stairway Illumination: All interior and exterior stairways shall be provided with means to illuminate the stairway.

SECTION 7.

SECTION 2.4.170 – Hazardous locations (former title) *is amended to read as follows:*

Sec. 2.4.170 – Reserved.

SECTION 8.

SECTION 2.4.225 – Drainage *is added to read as follows:*

Section R310.2.2 of the International Residential Code is amended to read as follows:

R310.2.2 Drainage. Window wells shall be designed for proper drainage by connecting to the existing foundation drainage system required by Section R405.1 or by an approved alternative method. If no existing foundation drainage system has been installed, the entire window well area shall have a minimum depth of 12" of washed gravel or crushed rock below the floor level.

Exception: A drainage system for window wells is not required when the foundation is on well-drained soil or sand-gravel mixture soils according to the U.S. Soil Classification System, Group I Soils, as detailed in Table 405.1.

SECTION 9.

SECTION 2.4.230 – Landings at doors *is amended to read as follows:*

Section R311.3.1 of the International Residential Code is amended to read as follows:

R311.3.1 Floor elevations at the required egress doors. The floor or landing at the exterior door shall not be more than 1.5 inches (38 mm) lower than the top of the threshold. The landing shall be permitted to have a slope not to exceed 0.25 unit vertical in 12 units horizontal (2-percent).

Exceptions:

The exterior landing at an exterior doorway shall not be more than 8 (203 mm) inches below the top of the threshold, provided that the door, other than an exterior storm or screen door, does not swing over the landing.

SECTION 10.

SECTION 2.4.235 – Floor elevations for other exterior doors *is added to read as follows:*

Section R311.3.2 of the International Residential Code is amended to read as follows:

R311.3.2 Floor elevations for other exterior doors. Doors other than the required egress door shall be provided with landings or floors not more than 8 inches below the top of the threshold.

Exception:

A landing is not required where a stairway of four or fewer risers is located on the the door, provided the door does not swing over the stairway.

SECTION 11.

SECTION 2.4.240. – Riser height *is amended to read as follows:*

Section R311.7.5.1 of the International Residential Code is amended to read as follows:

Riser height: The maximum riser height shall be 8 (203 mm) inches. The riser shall be measured vertically between leading edges of the adjacent treads. The greatest riser height within any flight of stairs shall not exceed the smallest by more than 3/8 inch (9.5 mm).

SECTION 12.

SECTION 2.4.250. – Tread depth *is amended to read as follows:*

Sections R311.7.5.2 and R3.11.7.5.2.1 of the International Residential Code are amended to read as follows:

R311.7.5.2 Tread depth. The minimum tread depth shall be 9 inches (228.6 mm). The tread depth shall be measured horizontally between the vertical planes of the foremost projection of adjacent treads and at a right angle to the tread's leading edge. The greatest tread depth within any flight of stairs shall not exceed the smallest by more than 3/8 inch (9.5 mm).

R311.7.5.2.1 Winder and circular treads. Winder and circular treads shall have a minimum tread depth of 9 inches (228.6 mm) measured as above at a point 12 inches (305 mm) from the side where the treads are narrower. Winder and circular treads shall have a minimum tread depth of 6 inches (152 mm) at any point. Within any flight of stairs, the largest winder or circular tread depth at the 12-inch (305 mm) walk line shall not exceed the smallest by more than 3/8 inch (9.5 mm).

SECTION 13.

SECTION 2.4.270. – Landings for stairways (former title) *is amended to read as follows:*

Sec. 2.4.270. – Reserved.

SECTION 14.

SECTION 2.4.280. – Handrails *is amended to read as follows:*

Section R311.7.8.1 of the International Residential Code is amended to read as follows:

R311.7.8.1 Height. Handrail height, measured vertically from the sloped plane adjoining the tread nosing, or finished surface of ramp slope, shall be not less than 32 inches (864 mm) and not more than 38 inches (965 mm).

Exceptions:

1. The use of a volute, turnout or starting easing shall be allowed over the lowest tread.
2. When handrail fittings or bendings are used to provide continuous transition between flights, transitions at winder treads, the transition from handrail to guardrail, or used at the start of a flight, the handrail height at the fittings or bendings shall be permitted to exceed the maximum height.

SECTION 15.

SECTION 2.4.290. – Handrails continuity is amended to read as follows:

Section R311.7.8.2 of the International Residential Code is amended to read as follows:

R311.7.8.2 Continuity. Handrails for stairways shall be continuous for the full length of the flight, from a point directly above the top riser of the flight to a point directly above the lowest riser of the flight. Handrail ends shall be returned to the wall or shall terminate in newel posts or safety terminals at the top of each flight of stairs. Handrails adjacent to a wall shall have a space of not less than 1.25 (32.5mm) inches between the wall and the handrails.

Graspable portions of the handrail may not end up completely continuous from the top riser to the bottom riser. The rail shall return to the wall.

Exceptions:

- (1) Handrails shall be permitted to be interrupted by a newel post at the turn.
- (2) The use of a volute, turnout or starting easing, or starting newel shall be allowed over the lowest tread.

SECTION 16.

SECTION 2.4.300. – Handrail grip size is amended to read as follows:

Section R311.7.8.3 of the International Residential Code is amended to read as follows:

R311.7.8.3 Handrail grip size. All required handrails shall be of one of the following types or provide equivalent graspability.

1. Type I. Handrails with a circular cross section shall have an outside diameter of at least 1¼ inches (32 mm) and not greater than 2 inches (51 mm). If the handrail is not circular it shall have a perimeter dimension of at least 4 inches (102 mm) and not greater than 6¼ inches (160 mm) with a maximum cross section of dimension of 2¼ inches (57 mm).
2. Type II. Handrails with a perimeter greater than 6¼ inches (160 mm) shall provide a graspable finger recess area on the outboard side of the profile. The finger recess shall begin within a distance of ¾ inch (19 mm) measured vertically from the tallest portion of the profile and achieve a depth of at least 5/16 inch (8 mm) within 7/8 inch (22 mm) below the widest portion of the profile. This required depth shall continue for at least 3/8 inch (9.5 mm) to a level that is not less than 1¾ inches (45 mm) below the tallest portion of the profile. The minimum width of the handrail above the recess shall be 1¼ inches (32 mm) to a maximum of 2¾ inches (70 mm). Edges shall have a minimum radius of 0.01 inch (0.25 mm).

SECTION 17.

SECTION 2.4.310. – Guard opening limitations *is amended to read as follows:*

Section R312.1.3 of the International Residential Code is amended to read as follows:

R312.1.3 Guard opening limitations. Required guards on open sides of stairways, raised floor areas, balconies and porches shall have intermediate rails or ornamental closures which do not allow passage of a sphere 4 ½ inches (114.3 mm) or more in diameter. Required guards shall not be constructed with horizontal rails or other ornamental pattern that results in a ladder effect.

Exceptions:

1. The triangular openings formed by the riser, tread and bottom rail of a guard at the open side of a stairway are permitted to be of such a size that a sphere 6 inches (152 mm) cannot pass through.
2. Openings for required guards on the sides of stair treads shall not allow sphere 4 ½ inches (114.3 mm) to pass through.

SECTION 18.

SECTION 2.4.315. – Sec. R312.2 deleted *is created to read as follows:*

Section R312.2 Window fall protection of the International Residential Code is hereby deleted in its entirety.

SECTION 19.

SECTION 2.4.318. – Sec. R313 deleted *is created to read as follows:*

Section R313 Automatic fire sprinkler systems of the International Residential Code is hereby deleted in its entirety.

SECTION 20.

SECTION 2.4.320. – Single- and multiple-station smoke alarms *is amended to read as follows:*

Section R314.3 of the International Residential Code is amended to read as follows:

R314.3 Location. Single and multiple-station smoke alarms shall be installed in the following locations:

1. Outside of each separate sleeping area in the immediate vicinity of the bedrooms.
2. On each additional story of the dwelling, including basements and cellars but not including crawl spaces and uninhabitable attics. In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.

SECTION 21.

SECTION 2.4.325. – Interconnection *is added to read as follows:*

R314.5 Interconnection. Where more than one smoke alarm is required to be installed within an individual dwelling unit in accordance with Section R314.3, the alarm devices shall be interconnected in such a manner that the actuation of one alarm will activate all of the alarms in the individual unit. Physical interconnection of smoke alarms shall not be required where wireless alarms are installed & all alarms sound on activation of one alarm. The alarm shall be clearly audible in all bedrooms over background noise levels with all intervening doors closed.

SECTION 22.

SECTION 2.4.332. – Carbon monoxide alarms *is added to read as follows:*

R315.1 Carbon monoxide alarms of the International Residential Code is amended to read as follows:

R315.1 Carbon monoxide alarms. For new construction, an approved carbon monoxide alarm shall be installed in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages in the following locations:

1. Outside each sleeping room in the immediate vicinity of the bedrooms.
2. On each additional story of the dwelling, including basements in the immediate vicinity of the bedrooms or mechanical room.

SECTION 23.

SECTION 2.4.335. – Section R315.3 deleted *is added to read as follows:*

Section R315.3 of the International Residential Code is hereby deleted in its entirety. Carbon monoxide detectors are not required in existing homes.

SECTION 24.

SECTION 2.4.350. – Protection against decay *is amended to read as follows:*

Section R317.1 of the International Residential Code is amended to read as follows:

R317.1 Location required. Protection from decay shall be provided in the following locations by the use of naturally durable wood or wood that is preservative treated in accordance with AWP A U1 for the species, product, preservative and end use. Preservatives shall be listed in Section 4 of AWP A U1.

1. Wood joists or the bottom of a wood structural floor when closer than 18 inches (457 mm) or wood girders when closer than 12 inches (305 mm) to the exposed ground in crawl spaces or unexcavated area located within the periphery of the building foundation.
2. All wood framing members that rest on concrete or masonry exterior foundation walls and are less than 6 inches (152 mm) from the exposed ground.
3. Sills and sleepers on a concrete or masonry slab that is in direct contact with the ground unless separated from such slab by an impervious moisture barrier.

4. The ends of wood girders entering exterior masonry or concrete walls having clearances of less than 0.5 inch (12.7 mm) on tops, sides and ends.
5. Wood siding, sheathing and wall framing on the exterior of a building having a clearance of less than 6 inches (152 mm) from the ground.
6. Wood structural members supporting moisture-permeable floors or roofs that are exposed to the weather, such as concrete or masonry slabs, unless separated from such floors or roofs by an impervious moisture barrier.

SECTION 25.

SECTION 2.4.360. – Section R319.1.1 deleted (former title) is amended to read as follows:

Sec. 2.4.360. – Section R318.1.1 deleted.

Section R318.1.1 of the International Residential Code is hereby deleted.

SECTION 26.

SECTION 2.4.370. – Section R320.1.2 deleted (former title) is amended to read as follows:

Sec. 2.4.370. – Section R318.1.2 deleted.

Section R318.1.2 of the International Residential Code is hereby deleted.

SECTION 27.

SECTION 2.4.380. – Section R324 deleted (former title) is amended to read as follows:

Sec. 2.4.380. – Section R322 deleted.

Section R322 of the International Residential Code is hereby deleted.

SECTION 28.

SECTION 2.4.455. – Section R405.1 deleted is added to read as follows:

Sec. 2.4.455. – Section R405.1 deleted.

Section R405.1 of the International Residential Code is hereby deleted.

SECTION 29.

SECTION 2.4.480. – Section R502.2.2 created (former title) is amended to read as follows:

Sec. 2.4.480. – Decks.

Section R507 of the International Residential Code is amended to read as follows:

R507 Decks. The "City of Wichita Standard for Residential Wood Framed Decks" may be used to design and construct decks to comply with the requirements of this section. Decks which fall outside of the scope of the standard will require design by a Kansas licensed architect or engineer. Where supported by attachment to an exterior wall, decks shall be positively anchored to the primary structure and designed for both vertical and lateral loads as applicable. Such attachment shall not be accomplished by the use of toenails or nails subject to withdrawal. Where positive connection to the primary building structure cannot be verified during inspection, decks shall be self-supporting. For decks with cantilevered framing members, connections to exterior walls or other framing members, shall be designed and constructed to resist uplift resulting from the full live load specified in Table R301.5 acting on the cantilevered portion of the deck.

SECTION 30.

SECTION 2.4.490. – Section R506.2.3 deleted (former title) is amended to read as follows:

Sec. 2.4.490. – Section R506.2.2 deleted.

Section R506.2.2 of the International Residential Code is hereby deleted.

SECTION 31.

SECTION 2.4.510. – Cement, fiber-cement and glass mat gypsum backers is amended to read as follows:

Section R702.4.2 of the International Residential Code is amended to read as follows:

R702.4.2 Cement, fiber-cement or glass mat gypsum backers in compliance with ASTM C 1288, C 1325 or C 1178 and installed in accordance with manufacturers'

recommendations shall be used as backers for wall tile in shower areas and wall panels in shower areas.

SECTION 32. Exclusion of “hoop houses” from building code requirements *is added and reads as follows:*

SECTION 2.4.035 – Exclusion of “hoop houses” from building code requirements.

A “hoop house” is defined as the following: A poly-tunnel (also known as a poly-house, hoop greenhouse or hoop house, or high tunnel) made of polyethylene usually semi-circular, square or elongated in shape. The interior heats up due to solar radiation from the sun, thus warming plants, soil, and other things inside the building faster than heat can escape the structure. Air warmed by the heat from hot interior surfaces is retained in the building by the roof and wall. Hoop houses, within this definition, are for residential use only.

Structures that meet the definition of “hoop houses” are exempted from building permit requirements or engineering specifications within this jurisdiction.

SECTION 33. Publication.

Upon the adoption of this Resolution, the Clerk of Sedgwick County shall publish this Resolution once in the official county newspaper. This Resolution shall take effect on the 1st day of July, 2015.

Commissioners present and voting were:

DAVID M. UNRUH
TIM R. NORTON
KARL PETERJOHN
RICHARD RANZAU
JAMES M. HOWELL

Aye
Aye
Aye
Aye
Aye

Dated this 20th day of Nov, 2015.

ATTEST:

Karen B Bailey
for KELLY B. ARNOLD, County Clerk



BOARD OF COUNTY COMMISSIONERS
OF SEDGWICK COUNTY, KANSAS

Richard Ranzau
RICHARD RANZAU, Chairman
Commissioner, Fourth District

Karl Peterjohn
KARL PETERJOHN, Chair Pro Tem
Commissioner, Third District

APPROVED AS TO FORM:

Justin M. Waggoner
Justin M. Waggoner,
Assistant County Counselor

David M. Unruh
DAVID M. UNRUH
Commissioner, First District

Tim R. Norton
TIM R. NORTON
Commissioner, Second District

James M. Howell
JAMES M. HOWELL
Commissioner, Fifth District

Published in The Wichita Eagle,
Friday, May 29, 2015 (3350676)
RESOLUTION NO. 106-2-15
Date Adopted: May 20, 2015
Date Published: May 29, 2015
Date Effective: July 01, 2015

A RESOLUTION ADOPTING THE INTERNATIONAL RESIDENTIAL CODE, PUBLISHED BY THE INTERNATIONAL CODE COUNCIL, INC., 2012 EDITION, AND AMENDING, ADDING, AND DELETING VARIOUS SECTIONS OF ARTICLE 2 OF THE WICHITA/SEDGWICK COUNTY UNIFIED BUILDING AND TRADE CODE.

WHEREAS, the Board of County Commissioners is authorized by K.S.A. 19-101 et seq. and 12-3303 et seq. to officially adopt, incorporate, and promulgate by resolution codes, rules and regulations for air conditioning, refrigeration, warm air heating, and related trades within the confines of the unincorporated areas of Sedgwick County and those second- and third-class cities that have adopted those codes, rules, and regulations by action of their governing bodies and have entered into agreements with Sedgwick County related thereto; and

WHEREAS, effective January 1, 2013, Sedgwick County and the City of Wichita consolidated code enforcement from their respective jurisdictions within the Metropolitan Area Building and Construction Department ("MABCD") in Sedgwick County Resolution No. 135-2012 and City of Wichita Ordinance No. 49-333; and

WHEREAS, Sedgwick County, Kansas, and the City of Wichita, Kansas, have hereby adopted the Wichita-Sedgwick County Unified Building and Trade Code ("UBTC") within Resolution No. 175-2012 and Ordinance No. 49-412; and

WHEREAS, within the UBTC, Sedgwick County and the City of Wichita has previously adopted the International Residential Code, as published by the International Code Council, Inc., 2006 Edition, with additions, modifications, deletions, and omissions; and

WHEREAS, the MABCD Board of Code Standards and Appeals has reviewed and voted to approve all of the changes proposed in this Resolution; and

WHEREAS, the Board of County Commissioners of Sedgwick County, Kansas, finds that it has been advised by the Director of the MABCD, and therefore deems it necessary to amend the Article 2—Building Code portion of the UBTC by adopting the International Residential Code, published by the International Code Council, Inc., 2012 Edition, in place of the 2006 Edition of the same publication, with additions, modifications, deletions, and omissions as noted within this Resolution.

NOW, THEREFORE, BE IT RESOLVED THAT THE BOARD OF COUNTY COMMISSIONERS OF SEDGWICK COUNTY, KANSAS, AMENDS THE WICHITA-SEDGWICK COUNTY UNIFIED BUILDING AND TRADE CODE AS FOLLOWS:

SECTION 1.

SECTION 2.4.010. - Adoption of the International Residential Code is amended to read as follows:

The International Residential Code, as published by International Code Council, Inc., 2012 Edition, is hereby adopted, subject to such amendments as set forth hereinafter.

SECTION 2.

SECTION 2.4.020 - Permit required is amended to read as follows:

R105.1 Required. Any owner or authorized agent who intends to construct, enlarge, alter, repair, move, demolish, or change the occupancy of a building or structure, or to erect, install, enlarge, alter, repair, remove, convert or replace any electrical, gas, mechanical or plumbing system, or to cause any such work to be done, shall first make application to the building official and obtain the required permit.

Wichita Jurisdiction Only

Whenever any work for which a permit is required by this Code has commenced without first obtaining said permit, a civil penalty fee up to the amount of the permit fee, as determined by the Code Official, shall be collected in addition to the permit fee.

SECTION 3.

SECTION 2.4.130. - Exterior Walls is deleted.

SECTION 4.

SECTION 2.4.135 - Three- and Four-family Dwellings is added to read as follows:

Sec. R302.3.2 of the International Residential Code is hereby added to read as follows:
Dwelling units in three- and four-family dwellings shall be separated from each other by a wall having not less than a two-hour fire-resistance rating. Fire-resistance-rated floor/ceiling and wall assemblies shall extend to and be tight against an exterior wall, and wall assemblies shall extend from the foundation to the underside of the roof sheathing.

The roof shall be a minimum of class C roof covering, and the roof decking or sheathing is of non-combustible materials or approved fire-retardant-treated wood for a minimum distance of two feet from the center of the wall. There shall be no penetrations through this area of the roof deck or sheathing.

Exception: Where buildings, or portions thereof, are arranged above or below adjacent units, an automatic sprinkler system shall be provided throughout all units.

SECTION 5.

SECTION 2.4.138 - Opening Protection is added to read as follows:

Section R302.5.1 of the International Residential Code is amended to read as follows:

R302.5.1 Opening protection. Openings from a private garage directly into a room used for sleeping purposes shall not be permitted. Other openings between the garage and residence shall be equipped with solid wood doors not less than 3/8 (35 mm) in thickness, solid or honeycomb-core steel doors not less than 1 3/8 inches (35 mm) thick, or 20-minute fire-rated doors.

SECTION 6.

SECTION 2.4.160 - Stairway Illumination is amended to read as follows:

Section R303.7 of the International Residential Code is amended to read as follows:

R303.7 Stairway illumination: All interior and exterior stairways shall be provided with means to illuminate the stairway.

SECTION 7.

SECTION 2.4.170 - Hazardous locations (former title) is amended to read as follows:

Sec. 2.4.170 - Reserved.

SECTION 8.

SECTION 2.4.225 - Drainage is added to read as follows:

Section R310.2.2 of the International Residential Code is amended to read as follows:

R310.2.2 Drainage. Window wells shall be designed for proper drainage by connecting to the existing foundation

2. Type II Handrails with a perimeter greater than 6/4 inches (160 mm) shall provide a graspable finger recess area on the outboard side of the profile. The finger recess shall begin within a distance of 3/4 inch (19 mm) measured vertically from the tallest portion of the profile and achieve a depth of at least 5/16 inch (8 mm) within 7/8 inch (22 mm) below the widest portion of the profile. This required depth shall continue for at least 3/8 inch (9.5 mm) to a level that is not less than 1 1/4 inches (45 mm) below the tallest portion of the profile. The minimum width of the handrail above the recess shall be 1 1/4 inches (32 mm) to a maximum of 2 1/4 inches (70 mm). Edges shall have a minimum radius of 0.01 inch (0.25 mm).

SECTION 17.

SECTION 2.4.310. - Guard opening limitations is amended to read as follows:

Section R312.1.3 of the International Residential Code is amended to read as follows:

R312.1.3 Guard opening limitations. Required guards on open sides of stairways, raised floor areas, balconies and porches shall have intermediate rails or ornamental closures which do not allow passage of a sphere 4 1/2 inches (114.3 mm) or more in diameter. Required guards shall not be constructed with horizontal rails or other ornamental pattern that results in a ladder effect.

Exceptions:

1. The triangular openings formed by the riser, tread and bottom rail of a guard at the open side of a stairway are permitted to be of such a size that a sphere 6 inches (152 mm) cannot pass through.
2. Openings for required guards on the sides of stair treads shall not allow sphere 4 1/2 inches (114.3 mm) to pass through.

SECTION 18.

SECTION 2.4.315. - Sec. R312.2 deleted is created to read as follows:

Section R312.2 Window fall protection of the International Residential Code is hereby deleted in its entirety.

SECTION 19.

SECTION 2.4.318. - Sec. R313 deleted is created to read as follows:

Section R313 Automatic fire sprinkler systems of the International Residential Code is hereby deleted in its entirety.

SECTION 20.

SECTION 2.4.320. - Single- and multiple-station smoke alarms is amended to read as follows:

Section R314.3 of the International Residential Code is amended to read as follows:

R314.3 Location. Single and multiple-station smoke alarms shall be installed in the following locations:

1. Outside of each separate sleeping area in the immediate vicinity of the bedrooms.
2. On each additional story of the dwelling, including basements and cellars but not including crawl spaces and uninhabitable attics. In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm installed on the upper level shall suffice for the adjacent lower level provided that the lower level is less than one full story below the upper level.

SECTION 21.

SECTION 2.4.325. - Interconnection is added to read as follows:

R314.5 Interconnection. Where more than one smoke alarm is required to be installed within an individual dwelling unit in accordance with Section R314.3, the alarm devices shall be interconnected in such a manner that the activation of one alarm will activate all of the alarms in the individual unit. Physical interconnection of smoke alarms shall not be required where wireless alarms are installed & all alarms sound on activation of one alarm. The alarm shall be clearly audible in all bedrooms over background noise levels with all intervening doors closed.

SECTION 22.

SECTION 2.4.332. - Carbon monoxide alarms is added to read as follows:

R315.1 Carbon monoxide alarms of the International Residential Code is amended to read as follows:

R315.1 Carbon monoxide alarms. For new construction, an approved carbon monoxide alarm shall be installed in dwelling units within which fuel-fired appliances are installed and in dwelling units that have attached garages in the following locations:

1. Outside each sleeping room in the immediate vicinity of the bedrooms.
2. On each additional story of the dwelling, including basements in the immediate vicinity of the bedrooms or mechanical room.

SECTION 23.

SECTION 2.4.335. - Section R315.3 deleted is added to read as follows:

Section R315.3 of the International Residential Code is hereby deleted in its entirety. Carbon monoxide detectors are not required in existing homes.

SECTION 24.

SECTION 2.4.350. - Protection against decay is amended to read as follows:

Section R317.1 of the International Residential Code is amended to read as follows:
R317.1 Location required. Protection from decay shall be provided in the following locations by the use of naturally durable wood or wood that is preservative treated in accordance with AWPA U1 for the species, product, preservative and end use. Preservatives shall be listed in Section 4 of AWPA U1.

1. Wood joists or the bottom of a wood structural floor when closer than 18 inches (457 mm) or wood girders when closer than 12 inches (305 mm) to the exposed ground in crawl spaces or unexcavated area located within the periphery of the building foundation.
2. All wood framing members that rest on concrete or masonry exterior foundation walls and are less than 6 inches (152 mm) from the exposed ground.
3. Sills and sleepers on a concrete or masonry slab that is in direct contact with the ground unless separated from such slab by an impervious moisture barrier.
4. The ends of wood girders entering exterior masonry or concrete walls having clearances of less than 0.5 inch (12.7 mm) on tops, sides and ends.
5. Wood siding, sheathing and wall framing on the exterior of a building having a clearance of less than 6 inches (152 mm) from the ground.
6. Wood structural members supporting moisture-permeable floors or roofs that are exposed to the weather, such as concrete or masonry slabs, unless separated from such floors or roofs by an impervious moisture barrier.

SECTION 25.

SECTION 2.4.360. - Section R319.1.1 deleted (former title) is amended to read as follows:

Sec. 2.4.360. - Section R318.1.1 deleted.

Section R318.1.1 of the International Residential Code is hereby deleted.

SECTION 26.

SECTION 2.4.370. - Section R320.1.2 deleted (former title) is amended to read as follows:

Sec. 2.4.370. - Section R318.1.2 deleted.

Section R318.1.2 of the International Residential Code is hereby deleted.

drainage system required by Section R405.1 or by an approved alternative method. If no existing foundation drainage system has been installed, the entire window well area shall have a minimum depth of 12" of washed gravel or crushed rock below the floor level.

Exception: A drainage system for window wells is not required when the foundation is on well-drained soil or sand-gravel mixture soils according to the U.S. Soil Classification System, Group I Soils, as detailed in Table 405.1.

SECTION 9.

SECTION 2.4.230 - Landings at doors is amended to read as follows:

Section R311.3.1 of the International Residential Code is amended to read as follows:

R311.3.1 Floor elevations at the required egress doors. The floor or landing at the exterior door shall not be more than 1.5 inches (38 mm) lower than the top of the threshold. The landing shall be permitted to have a slope not to exceed 0.25 unit vertical in 12 units horizontal (2-percent).

Exceptions:

The exterior landing at an exterior doorway shall not be more than 8 (203 mm) inches below the top of the threshold, provided that the door, other than an exterior storm or screen door, does not swing over the landing.

SECTION 10.

SECTION 2.4.235 - Floor elevations for other exterior doors is added to read as follows:

Section R311.3.2 of the International Residential Code is amended to read as follows:

R311.3.2 Floor elevations for other exterior doors. Doors other than the required egress door shall be provided with landings or floors not more than 8 inches below the top of the threshold.

Exception:

A landing is not required where a stairway of four or fewer risers is located on the line door, provided the door does not swing over the stairway.

SECTION 11.

SECTION 2.4.240. - Riser height is amended to read as follows:

Sections R311.7.5.1 of the International Residential Code is amended to read as follows:

Riser height: The maximum riser height shall be 8 (203 mm) inches. The riser shall be measured vertically between leading edges of the adjacent treads. The greatest riser height within any flight of stairs shall not exceed the smallest by more than 3/8 inch (9.5 mm).

SECTION 12.

SECTION 2.4.250. - Tread depth is amended to read as follows:

Sections R311.7.5.2 and R311.7.5.2.1 of the International Residential Code are amended to read as follows:

R311.7.5.2 Tread depth. The minimum tread depth shall be 9 inches (228.6 mm). The tread depth shall be measured horizontally between the vertical planes of the foremost projection of adjacent treads and at a right angle to the tread's leading edge. The greatest tread depth within any flight of stairs shall not exceed the smallest by more than 3/8 inch (9.5 mm).

R311.7.5.2.1 Winder and circular treads. Winder and circular treads shall have a minimum tread depth of 9 inches (228.6 mm) measured as above at a point 12 inches (305 mm) from the side where the treads are narrower. Winder and circular treads shall have a minimum tread depth of 6 inches (152 mm) at any point. Within any flight of stairs, the largest winder or circular tread depth at the 12-inch (305 mm) walk line shall not exceed the smallest by more than 3/8 inch (9.5 mm).

SECTION 13.

SECTION 2.4.270. - Landings for stairways (former title) is amended to read as follows:

Sec. 2.4.270. - Reserved.

SECTION 14.

SECTION 2.4.280. - Handrails is amended to read as follows:

Section R311.7.8.1 of the International Residential Code is amended to read as follows:

R311.7.8.1 Height. Handrail height, measured vertically from the sloped plane adjoining the tread nosing, or finished surface of ramp slope, shall be not less than 32 inches (864 mm) and not more than 38 inches (965 mm).

Exceptions:

1. The use of a volute, turnout or starting easing shall be allowed over the lowest tread.
2. When handrail fittings or bendings are used to provide continuous transition between flights, transitions at winder treads, the transition from handrail to guardrail, or used at the start of a flight, the handrail height at the fittings or bendings shall be permitted to exceed the maximum height.

SECTION 15.

SECTION 2.4.290. - Handrails continuity is amended to read as follows:

Section R311.7.8.2 of the International Residential Code is amended to read as follows:

R311.7.8.2 Continuity. Handrails for stairways shall be continuous for the full length of the flight, from a point directly above the top riser of the flight to a point directly above the lowest riser of the flight. Handrail ends shall be returned to the wall or shall terminate in newel posts or safety terminals at the top of each flight of stairs. Handrails adjacent to a wall shall have a space of not less than 1.25 (32.5mm) inches between the wall and the handrails.

Graspable portions of the handrail may not end up completely continuous from the top riser to the bottom riser. The rail shall return to the wall.

Exceptions:

- (1) Handrails shall be permitted to be interrupted by a newel post at the turn.
- (2) The use of a volute, turnout or starting easing, or starting newel shall be allowed over the lowest tread.

SECTION 16.

SECTION 2.4.300. - Handrail grip size is amended to read as follows:

Section R311.7.8.3 of the International Residential Code is amended to read as follows:

R311.7.8.3 Handrail grip size. All required handrails shall be of one of the following types or provide equivalent graspability.

1. Type I. Handrails with a circular cross section shall have an outside diameter of at least 1 1/4 inches (32 mm) and not greater than 2 inches (51 mm). If the handrail is not circular it shall have a perimeter dimension of at least 4 inches (102 mm) and not greater than 6 1/4 inches (160 mm) with a maximum cross section of dimension of 2 1/4 inches (57 mm).

SECTION 27.

SECTION 2.4.380. - Section R324 deleted (former title) is amended to read as follows:

Sec. 2.4.380. - Section R322 deleted.

Section R322 of the International Residential Code is hereby deleted.

SECTION 28.

SECTION 2.4.455. - Section R405.1 deleted is added to read as follows:

Sec. 2.4.455. - Section R405.1 deleted.

Section R405.1 of the International Residential Code is hereby deleted.

SECTION 29.

SECTION 2.4.480. - Section R502.2.2 created (former title) is amended to read as follows:

Sec. 2.4.480. - Decks.

Section R507 of the International Residential Code is amended to read as follows:

R507 Decks. The "City of Wichita Standard for Residential Wood Framed Decks" may be used to design and construct decks to comply with the requirements of this section. Decks which fall outside of the scope of the standard will require design by a Kansas licensed architect or engineer. Where supported by attachment to an exterior wall, decks shall be positively anchored to the primary structure and designed for both vertical and lateral loads as applicable. Such attachment shall not be accomplished by the use of toenails or nails subject to withdrawal. Where positive connection to the primary building structure cannot be verified during inspection, decks shall be self-supporting. For decks with cantilevered framing members, connections to exterior walls or other framing members, shall be designed and constructed to resist uplift resulting from the full live load specified in Table R301.5 acting on the cantilevered portion of the deck.

SECTION 30.

SECTION 2.4.490. - Section R506.2.3 deleted (former title) is amended to read as follows:

Sec. 2.4.490. - Section R506.2.2 deleted.

Section R506.2.2 of the International Residential Code is hereby deleted.

SECTION 31.

SECTION 2.4.510. - Cement, fiber-cement and glass mat gypsum backers is amended to read as follows:

Section R702.4.2 of the International Residential Code is amended to read as follows:

R702.4.2 Cement, fiber-cement or glass mat gypsum backers in compliance with ASTM C 1288, C 1325 or C 1178 and installed in accordance with manufacturers' recommendations shall be used as backers for wall tile in shower areas and wall panels in shower areas.

SECTION 32. Exclusion of "hoop houses" from building code requirements is added and reads as follows:

SECTION 2.4.035 - Exclusion of "hoop houses" from building code requirements.

A "hoop house" is defined as the following: A poly-tunnel (also known as a poly-house, hoop greenhouse or hoop house, or high tunnel) made of polyethylene usually semi-circular, square or elongated in shape. The interior heats up due to solar radiation from the sun, thus warming plants, soil, and other things inside the building faster than heat can escape the structure. Air warmed by the heat from hot interior surfaces is retained in the building by the roof and wall. Hoop houses, within this definition, are for residential use only.

Structures that meet the definition of "hoop houses" are exempted from building permit requirements or engineering specifications within this jurisdiction.

SECTION 33. Publication.

Upon the adoption of this Resolution, the Clerk of Sedgwick County shall publish this Resolution once in the official county newspaper. This Resolution take effect on the 1st day of July, 2015.

Commissioners present and voting were:

DAVID M. UNRUH	AYE
TIM R. NORTON	AYE
KARL PETERJOHN	AYE
RICHARD RANZAU	AYE
JAMES M. HOWELL	AYE

Dated this 20th day of May, 2015.

BOARD OF COUNTY COMMISSIONERS
OF SEDGWICK COUNTY, KANSAS

ATTEST:

KELLY B. ARNOLD, County Clerk

RICHARD RANZAU, Chairman
Commissioner, Fourth District

APPROVED AS TO FORM:

Justin M. Waggoner,
Assistant County Counselor

KARL PETERJOHN, Chair Pro Tem
Commissioner, Third District

DAVID M. UNRUH
Commissioner, First District

TIM R. NORTON
Commissioner, Second District

JAMES M. HOWELL
Commissioner, Fifth District