


EQUIPMENT CONNECTION SCH

SVA

UNIT DESIG.	120/60/1	277/60/1	480/60/3	208/60/1	LOAD			PANEL DEVICE RATING (AMPS/POLE)								DISCONNECTING DEVICE AT UNIT (AMP)						
					H.P.	FLA	MCA	20/1	20/1 GFI	20/3	800/3	125/3	50/3	80/3	30/3	20/2	FU STAT	30/3	60/3	800/3	100/3	30/2
8 FPVAV-1A	●				FR			●										3				
8 FPVAV-1B	●				FR			●										3				
8 FPVAV-1C	●				FR			●										3				
8 FPVAV-2	●				FR			●										3				
8 FPVAV-8	●				FR			●										3				
8 FPVAV-13	●				FR			●										3				
8 FPVAV-18A	●				FR			●										3				
8 FPVAV-18B	●				FR			●										3				
8 FPVAV-18C	●				FR			●										3				
8 FPVAV-18D	●				FR			●										3				
8 FPVAV-24A	●				FR			●										3				
8 FPVAV-25A	●				FR			●										3				
8 FPVAV-25B	●				FR			●										3				
8 FPVAV-24B	●				FR			●										3				
5 EF-1	●				1/6			●														
5 EF-17	●				1/6			●														
DST-3		●			40	52																SW
DST-4		●			25	34																SW
DST-5		●			25	34																SW
PCWP-3		●			10	14				●												SW
PCWP-4		●			10	14				●												SW
SCWP-4		●			15	21																SW
SCWP-5		●			15	21																SW
SCWP-6		●			15	21																SW
GFA-4	●				1/2			●														

ADDENDUM #2

JOEL DeHAVEN
 LICENSED
 18950
 11-7-08
 KANSAS
 PROFESSIONAL ENGINEER



TAYLOR RYMAR
 CORPORATION
 200 NORTH BROADWAY
 SUITE 330
 WICHITA, KS 67202
 PH: 316.771.5011 FAX: 316.771.5012
 WWW.TRM-CORP.COM
 TRC Project No. 100016.00
 Copyright 2008 Taylor RyMar Corporation

SCHAEFER JOHNSON COX FREY ARCHITECTURE
 Empress Center
 257 N. Broadway
 Wichita, Kansas
 67202-2317
 Ph: 316.854.0171
 Fax: 316.854.8835
 www.sjcf.com
 architecture@sjcf.com

PRJ NO. 2955.00
**NATIONAL CENTER
 FOR AVIATION TRAINING
 JABARA CAMPUS**
 WEBB ROAD
 WICHITA, KANSAS

REV. 7 NOV. 08

E52.7a

