



SEDGWICK COUNTY, KANSAS
DIVISION OF FINANCE
PURCHASING DEPARTMENT

525 N. Main, Suite 823 ~ Wichita, KS 67203
Phone: 316 660-7255 Fax: 316 383-7055

www.sedgwickcounty.org/purchasing

Addendum Number Two
To The Drawings and Specifications for
RFB 14-0054 LAKE AFTON ADA UPGRADES

Issued: Tuesday June 17, 2014

HANNEY & ASSOCIATES ARCHITECTS
1726 South Hillside, Wichita, Kansas

NOTICE TO BIDDERS

You are hereby instructed to include in your bids the following changes and/or corrections to the Drawings and Specifications for the Faith Mennonite Church.

The additions and/or corrections shall be considered as a part of the Contract Documents as if incorporated therein. Where the following corrections and/or additions vary from the conditions of the Drawings and Specifications, such following changes or additions shall govern.

I. GENERAL CLARIFICATIONS:

- 1.1 Please check the Sedgwick County website for a downloadable addendum information including any addendum-issued drawings and documents.
- 1.2 The bid date, time and location remain unchanged.
- 1.3 **Code Compliance:**
This group of projects are to be constructed in a manor that is compliant with the requirements of the 2010 American's with Disabilities Act.
- 1.4 **Dirt spoils:**
Excess dirt generated by the work on this group of projects shall be spread out on the site where they are generated. The location and extent of distribution shall be reviewed and approved by the Park Superintendent prior to doing the work.
- 1.5 **Electrical Wiring:**
 - 1.5.1 It shall be clarified that only copper wire shall be used on this project.
 - 1.5.2 The new electrical ties into the existing service. Refer to the electrical drawings that were issued with addendum one.
- 1.6 **Lake Elevation:**
The elevation of the lake varies. The Park Superintendent noted that on the day of the Pre-Bid meeting the lake was 18" below pool.

1.7 **Lake Events:**

There are multiple events planned at the lake that the contractor will be required to work around. All these events are scheduled over weekends not during the week.

1.8 **Sheet A**

1.8.1 The title for detail plan "A" shall be clarified to be "Accessible Fishing Dock" in lieu of Accessible Shelter & Dock.

1.8.2 The fencing and handrail around the dock area and accessible fishing dock shall be clarified to be galvanized steel. All references to aluminum shall be changed.

1.8.3 The deck material for the "Accessible Fishing Dock" shall be clarified to be the composite deck specified on this sheet in lieu of the treated 2x6 called for on the structural drawing. The deck purchased shall be rated for joists spaced at 20" on center, or the General Contractor shall change the joist spacing to accommodate the decks span.

1.9 **Sheet A4e.1**

Camp ground area – the detectable warning strip shall be deleted from this area to match the other picnic areas that are part of this project. The concrete paving shall fill the area occupied by the detectable warning strip in the unloading and access area.

Vendors are responsible for checking the web site and **acknowledging any addendums on the proposal response form.**



Kim Evans
Purchasing Agent