

**1. HEAT EXCHANGE REPLACEMENTS FOR ADULT DETENTION FACILITY - FACILITIES DEPARTMENT  
FUNDING - FACILITIES DEPARTMENT**

(Request sent to 101 vendors)

RFB # 17-0092 S/C #8000118642

	Central Mechanical Wichita LLC.	Kruse Corporation	P1 Group, Inc.	Five Star Mechanical, Inc.	South Central Commercial Mechanical , LLC
1. Materials and Labor to replace heat exchanger #2, per specifications	\$21,491.00	\$24,613.00	\$26,935.00	\$23,412.00	<b>\$18,986.12</b>
2. Materials and Labor to replace heat exchanger #5, per specifications	\$22,443.00	\$23,725.00	\$27,542.00	\$23,993.00	<b>\$19,809.62</b>
Labor to install owner provided heat exchanger #6	\$8,519.00	\$6,922.00	\$12,299.00	\$6,479.00	<b>\$2,874.08</b>
<b>Grand Total</b>	<b>\$52,453.00</b>	<b>\$55,260.00</b>	<b>\$66,776.00</b>	<b>\$53,884.00</b>	<b>\$41,669.82</b>
No Bid	Adams Electric & Plumbing Heat & Air	Cutting Edge Resources, Inc.	Decker & Mattison Co., Inc.	Kelly & Dawson	
	PMC	Reddi Industries, Inc.	Rod's Cooling & Heating	Total Filtration Services, Inc.	

The recommendation of Purchasing and Facilities is to accept the low bid from **South Central Commercial Mechanical, LLC in the amount of \$41,669.82.**

The heat exchanger is the part that includes the burner and tube bundle within a hot water heater. This assembly fits inside the water tank. When the water temperature falls below set point the burner kicks on and the heat is "exchanged" to the water tank. These need replaced due to leaks in the tube bundle which allows water from the tank into the burner assembly.