

## **DIVISION OF FINANCE - PURCHASING DEPARTMENT**

100 N. Broadway St, Suite 610 Wichita, KS 67202 • Phone (316) 660-7255 • Fax (316) 660-1839 
PURCHASING@SEDGWICK.GOV • SEDGWICKCOUNTY.ORG

# ADDENDUM #1 RFB #24-0081 ADULT DETENTION FACILITY LAUNDRY DRYER REPLACEMENTS AND BOILER REMOVAL

December 12, 2024

The following is to ensure that vendors have complete information prior to submitting a *bid*. Here are some clarifications regarding the bid for Adult Detention Facility Laundry Dryer Replacements and Boiler Removal for Facilities Maintenance.

Questions and/or statements of clarification are in **bold** font, and answers to specific questions are *italicized*.

#### Clarification from the pre-bid meeting held on December 10, 2024.

#### Under Section III. Scope of Work

The current dryers are built into place with detention grade materials behind the sheetrock wall. Any alterations to the wall structure are expected to be repaired and will be reviewed due to security reasons before vendor or subvendor covers the wall back with sheetrock. — Areas that need to be filled in due to gap issues must be filled using structural steel. Adult Detention Facility expects to be able to continue to provide laundry service during the project with the dryers that remain operational (currently two dryers are operational at this time) and flow seamlessly into the operation of the new dryers once installation is complete. \*\*Access into the facility will be through a pit from the outside of the building utilizing a crane or boom into the boiler room. \*\* Bidders shall include spec sheets on the new dryers and indicate how they will fit into the space when submitting a bid. Manufacturer dealers shall be located within Sedgwick County or a surrounding county to provide manufacturer support.

Welding is permitted – must have a hot work permit.

#### \*\*There are two (2) access points

The south entry has a removeable wall gaining access to the boiler room. Also the south entrance is where the boilers are located that we have asked to be removed as an optional bid.

The north entrance has an exercise area attached that has a steel wall that will need to be removed to gain access. If utilizing this option at the end of the day the wall must be replaced.

Firms interested in submitting a *bid*, must respond with complete information and **deliver on or before** 1:45 pm *CST*, *December 24*, 2024. Late *bids* will not be accepted and will not receive consideration for final award.

### "PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THE BID RESPONSE PAGE."

Tammy Culley Purchasing Agent

Tamara Culley

TC/ch